



Amp Rating	Equip. Class	Configuration		Min. Wire Type Allowed	Min. Wire Size (mm <sup>2</sup> )	Applicable Standard (IEC 60083)
		Cable	Appliance Inlet			
0.2	II	 C1	 C2	227IEC41	-	A 1-15 B C 5
2.5	I	 C5	 C6	227IEC52	0.75	A 5-15 B 2 C 2b C 3b C 4
2.5	II	 C7	 C8	224IEC52	0.75	A 1-15 B 2 C 5 C 6
6	II	 C9	 C10	227IEC52	0.75	A 1-15 B 2 C 6
10	I	 C13	 C14	227IEC53 or 249IEC53	0.75	A 5-15 B 2 C 2b C 3b C 4
10	I	 C15	 C16	249IEC53 or 249IEC51	0.75	A 5-15 B 2 C 2b C 3b C 4
10	II	 C17	 C18	227IEC53 or 249IEC53	0.75	A 1-15 B 2 C 6
16	I	 C19	 C20	227IEC53 or 249IEC53	1.0	A 5-15 B 2 C 2b C 3b C 4
16	I	 C21	 C22	249IEC53 or 249IEC51	1.0	A 5-15 B 2 C 2b C 3b C 4
16	II	 C23	 C24	227IEC53 or 249IEC53	1.0	A 1-15 B 2 C 6